



**NOTE:**

WHEN DRILLING EXISTING FOUNDATION FOR CONVERTING OVERHEAD FEED TO UNDERGROUND, CONDUITS SHALL BE A MINIMUM 3/4" PVC SCHED. 40. DRILLING SHALL BE LIMITED TO ONE.

 RICHARD G. SWEET R.C.E. 44,213 EXP. 6/30/07		3/17/05 DATE		<b>City of Santa Maria Standard Drawing</b>	
REVISIONS		BY APP DATE		DESCRIPTION: <b>NEW PULL BOX/ OVERHEAD CONVERSION WITH STREET LIGHT CONDUIT</b>	STANDARD NUMBER <b>SL-16</b>
DRAWN BY: M.K.		DATE DRAWN: 8/2000	SCALE: NONE	SHEET 6 OF 7	