


**A**

**NOTES:**

1. ENCLOSURE TO BE PIPELINE PRODUCTS VCAS-1830-SM OR AS APPROVED BY CITY ENGINEER.
2. LOCK FOR COVER BOX FURNISHED BY CITY.
3. SLOPE CONCRETE PAD FOR COVER BOX TO DRAIN AWAY FROM BOX.
4. PLACE PAD AND COVER BOX AT BACK OF PARKWAY OR BACK OF SIDEWALK.
5. INSTALL CTS COMPRESSION X MIP 2" BALL VALVE WITH BRASS THREADS, JONES OR APPROVED EQUAL WITH VALVE NUT ADAPTER WITH VALVE BOX AND RISER PER STANDARD DRAWING JUST DOWNSTREAM OF ELBOW AT CONNECTION TO MAIN.

**AIR & VACUUM RELEASE VALVE ASSEMBLY**  
NO SCALE

RICHARD G. SWEET R.C.E. 44,213 EXP. 6/30/07		11/22/04			<b>City of Santa Maria</b> <b>Standard Drawing</b>	
REVISIONS		BY	APP		DATE	DESCRIPTION:
A	UTILITY DEPT. REVISIONS	CJP		7/08	2" COMBINATION AIR & VACUUM RELEASE VALVE	
DRAWN BY: H.P.		DATE DRAWN: 7/71		SCALE: NONE		STANDARD NUMBER WA-26A
						SHEET 1 OF 1